



Township of Upper Dublin: Office of the Fire Marshal
801 Loch Alsh Avenue, Fort Washington, PA 19034
Voice: 215.643.1600 x 3210 Fax: 215.643.8843
e-mail: tschuck@upperdublin.net

ABOVE and UNDERGROUND STORAGE TANK(S) **INSTALLATION and REMOVAL**

AGST and UGST installation and removal work must be in completed in accordance with NFPA regulations and the requirements of the PA DEP Storage Tank Regulations.

The installation or removal of tanks shall be by a recognized contractor who is an experienced specialist in both installation and removal of either underground or above ground storage tanks.

ABGST and UGST Permit* application must include all of the following documents:

Removal

- 1) Copy of the contractors PA DEP Certification**
- 2) PA One Call notification prior to start of the project**
- 3) Upon completion of the removal a Closure Report must be submitted to the Office of the Fire Marshal in a timely fashion**

Installation

- 1) Cut sheets for equipment that is being installed and any attached appliances**
- 2) Copy of the contractors PA DEP Certification**
- 3) PA One Call notification prior to start of the project**
- 4) Installation shall be in accordance with the applicable NFPA and 2006 edition of International Fire Code**

The contractor or designee will pay any fees that are required before the start of the project.

The Fire Marshal must be contacted to perform all required inspections as outline in the applicable NFPA Code.

Additional information is available at www.state.pa.us, Keyword: DEP Storage Tanks.

Fee Schedule \$75.00 Per Tank

Please contact Fire Marshal Timothy Schuck with any questions.

*** The Fire Protection Systems Permit Application form can be found on the internet at Upperdublin.net. Click on Code Enforcement and then select Documents & Forms.**



Township of Upper Dublin - Office of the Fire Marshal
 801 Loch Alsh Avenue, Fort Washington, PA 19034 215-643-1600 x3210

Fire Protection Systems Permit Application

DATE: Fee: \$ Check# Permit #:

Project Name:

Project Location / Address:

City: State: PA Zip: Tax Parcel#:

Square Footage: Number of Stories: Construction Type:

PROJECT DESCRIPTION:

FIRE ALARM SPRINKLER-COMMERCIAL SPRINKLER-RESIDENTIAL SPECIAL HAZARD
 HOOD SYSTEM FIREPLACE CLEAN AGENT OTHER
 UGS/AGS TANK NEW RETROFIT / UPGRADE

Hazard Classification:

Occupancy Type: & Use Group:

Code Set: NFPA 101 NFPA 13 NFPA 13D NFPA 13R NFPA 13 NFPA 72 NFPA 96 PA UCC
 NFPA 14 NFPA 15 Other: _____ Date of Edition: _____

Fire Alarm System Only: LOCAL CENTRAL STATION PROPRIETARY REMOTE OTHER: _____
 Note: Submit 2 sets of NICET III I IV or PE Sealed Drawings; cut sheets

Sprinkler System Only: WET DRY DELUGE PREACTION FOAM
 Note: Submit 2 sets of NICET III I IV or PE Sealed Drawings; cut sheets; Hydraulic Calculations

Hood Suppression System Only: WET CHEMICAL WATER MIST OTHER: _____
 Note: Submit 2 sets of NICET III I IV or PE Sealed Drawings; cut sheets

Special Hazard System Only: CLEAN AGENT INERT GAS OTHER: _____
 Note: Submit 2 sets of NICET III / IV or PE Sealed Drawings; cut sheets

Applicant Name: Company:

Address / City / State / Zip:

Phone: Fax: Email:

Reviewed By: DATE: / /