

# Borough Of Ambler

131 Rosemary Avenue  
AMBLER, PENNSYLVANIA 19002

PHONE 215-646-1000  
FAX 215-641-1355 ADMINISTRATION  
FAX 215-641-1921 WATER DEPARTMENT  
WEBSITE: [www.boroughofambler.com](http://www.boroughofambler.com)



December 1, 2016

Paul Leonard  
Township Manager  
Upper Dublin Township  
801 Loch Alsh Avenue  
Ft. Washington, PA 19034

Dear Paul:

On October 31, 2016 Ambler Borough Water Department collected water samples from within our distribution system from all wells, our surface water facility and our water storage tanks. Samples were analyzed by Eurofins QC, Inc.

Ambler Borough's Water Engineer Stuart Rosenthal, P.E. of Gilmore & Associates, Inc. has reviewed the analytical report received last week from Eurofins for PFCs in the Ambler water system. Attached is a summary of the lab data. As you can see, the PFC concentrations are well below the EPA Health Advisory Limit of 70 ppt. Specifically, PFOS was not detected at any location and PFOA concentrations ranged from 4 to 13 ppt.

Our engineer is confident the results clearly document that PFCs are not a problem in Ambler water. Ambler Water Department has been aware of and responsive to this developing situation, we have tested our water supply and determined it to be safe. We are committed to providing our customers with a safe and reliable water supply.

Regards,

A handwritten signature in blue ink, appearing to read "Mary Aversa", is written over a light blue circular stamp.

Mary Aversa  
Borough Manager

**AMBLER WATER SYSTEM PFC CONCENTRATIONS**

<u>Well No. or Location</u>	PFOA Concentration <u>(ppt)</u>	PFOS Concentration <u>(ppt)</u>	EPA HAL Concentration <u>(ppt)</u>
2	13	ND	70
4	9	ND	70
6	9	ND	70
7	8	ND	70
8	4	ND	70
9	10	ND	70
11	8	ND	70
12	7	ND	70
14	6	ND	70
Loch Alsh Tank	12	ND	70
Broad Axe Tank	7	ND	70
Houston Road Tank	7	ND	70
Whitemarsh WTP	10	ND	70

Notes:

ppt=parts per trillion

ND=Not Detected

HAL=Health Advisory Limit (recommended limit for PFOA + PFOS concentrations)

All samples collected on October 31, 2016 and analyzed by Eurofins QC, Inc.