

AMBLER WATER SYSTEM PFC CONCENTRATIONS

<u>Well No. or Location</u>	<u>PFOA Concentration (ppt)</u>	<u>PFOS Concentration (ppt)</u>	<u>EPA HAL Concentration (ppt)</u>
2	13	ND	70
4	9	ND	70
6	9	ND	70
7	8	ND	70
8	4	ND	70
9	10	ND	70
11	8	ND	70
12	7	ND	70
14	6	ND	70
Loch Alsh Tank	12	ND	70
Broad Axe Tank	7	ND	70
Houston Road Tank	7	ND	70
Whitemarsh WTP	10	ND	70

Notes:

ppt=parts per trillion

ND=Not Detected

HAL=Health Advisory Limit (recommended limit for PFOA + PFOS concentrations)

All samples collected on October 31, 2016 and analyzed by Eurofins QC, Inc.